

FLOOD RISK ASSESSMENT 380KV STATIONS

TenneT manages the national high-voltage transport grid in the Netherlands. It consists of two rings: a smaller ring (220 kV and 380 kV) in the northeast of the country and a larger ring (380 kV) that more or less serves the rest of the Netherlands. Two 380 kV grids branch off from the larger ring: one serving the Randstad region and another serving the province of Zeeland.

The ring-shaped structure of the national grid has one important advantage: in the event of a power failure TenneT can continue to supply power to almost all of the Netherlands by reversing the direction of the electrical current. TenneT is working on extension of the capacity of the high-voltage grid. New lines and stations are constructed.

Svašek Hydraulics has executed several flood risk assessments to determine the construction height of new 380 kV stations. The construction height of new stations must be at such level that a station is able to operate, even when surrounding area is flooded. The consequences of failure of primary dikes, secondary dikes, flooding of a separate polder, and extreme

rainfall are taken into consideration. The flood risk of an individual station is considered together with the flood risk of the neighbouring stations. Svašek Hydraulics has investigated the flood risks for stations Lelystad, Wateringen, Borselle, Westerlee, Simonshaven, Breukelen, Bleiswijk and Eemshaven.

CLIENT

TenneT TSO

LOCATION

Various locations in the Netherlands

DATE

2003 - 2008

SERVICES

Flood risk assessment of construction height 380kV stations



SVASEK
HYDRAULICS
COASTAL, HARBOUR AND RIVER CONSULTANTS

Svašek Hydraulics
Kratonkade 23
3024 ES Rotterdam
the Netherlands

Phone: +31 10 467 13 61
Internet: www.svasek.com
E-mail: info@svasek.com